

Perform Rescue from a Live LV Panel

UETDRRF06B

- Element 1** **Prepare to perform rescue procedures from live LV panel**
- 1.1 Instruction in hazards and risk control measures for specific work functions and work areas are identified and obtained. (This will include the risk assessment and control measures taken by the individual performing the rescue).
 - 1.2 Electricity isolation point is identified and labelled where appropriate
 - 1.3 Tools and emergency equipment are checked for safety, functionality and placed in an accessible location to facilitate response and rescue according to established procedures.
- Element 2** **Carry out rescue from live LV Panel**
- 2.1 Workplace procedures and work instructions for controlling risk are followed.
 - 2.2 Workplace procedures for accessing and isolating the LV panel and removing the victim, where necessary, from contact with live apparatus are followed.
 - 2.3 Workplace procedures for applying CPR if required at the site and gaining access to treatment by a medical professional if necessary are followed.
 - 2.4 The worksite is secured and entry controlled until appropriate authorities inspect and release the site.
- Element 3** **Complete the LV panel rescue**
- 3.1 Processes for reporting accidents and/or incidents to authorised personnel are confirmed in accordance with established procedures.



37 Crescent Road, Waratah NSW 2298
PO Box 31 Kotara NSW 2289
Ph: 02-4960 9655
Fax: 02-4960 9655
Email: training@combinedsafety.com.au
ABN: 77 142 412 664 RTO No: 40453